

NOTES

A) ALL LIGHTING FIXTURES ARE ENERGY SAVING LIGHT FITTINGS.

GENERAL NOTES

- 1) LIGHTING WIRING CIRCUIT SHALL BE WIRED WITH 3x1.5mm² SINGLE CORE PVC COPPER CABLE AND MUST BE CABLE METAL OR APPROVED EQUAL.
- 2) CEILING FAN WIRING CIRCUIT SHALL BE WIRED WITH 3x1.5mm² SINGLE CORE PVC COPPER CABLE AND MUST BE CABLE METAL OR APPROVED EQUAL.
- 3) SOCKET OUTLET RING MAIN WIRING CIRCUIT SHALL BE WIRED WITH 6x2.5mm² SINGLE CORE PVC COPPER CABLE AND MUST BE CABLE METAL OR APPROVED EQUAL.
- 4) 15A S.S.O. SHALL BE WIRED USING 3x4mm² PVC CABLE
- 5) COOKER CONTROL CCT. SHALL BE WIRED USING 3x6mm² PVC CABLE AND BE PROTECTED IN CIRCUIT WITH 30A MCB.
- 6) WATER HEATER CIRCUIT SHALL BE WIRED USING 3x2.5MM² PVC CABLE AND BE PROTECTED IN CIRCUIT WITH 20A MCB.
- 7) EACH TELECOMMUNICATION CONDUIT POINT WIREWAYS SHALL BE INSTALLED USING 25mmØ UPVC STRAIGHT TOLLIT ROOM EXCEPT WHERE STATED OTHERWISE.


LIGHTING		POWER & MISCELLANEOUS		NOTE
SYMBOLS	DESCRIPTIONS	SYMBOLS	DESCRIPTIONS	
	2 x 18w CEILING MOUNTED Energy Saving FITT.		20A DOUBLE HOLE SWITCH OUTLET	ALL 15A A/C SWITCH SOCKET OUTLETS TO BE 1500mm ABOVE THE FINISH FLOOR, IF THE A/Cs ARE WINDOW UNIT. WHILE THE CABLE SIZE IS 4.0 mm sq PVC SINGLE CORE CABLE. BUT IF THE A/Cs ARE SPLIT UNIT, A 20A DOUBLE POLE SOCKET WITH AMBER LIGHT INSTEAD OF OF 15A.
	1 x 20w WALL-BRACKET FITTING		13A SWITCH SOCKET OUTLET	
	1 x 7w LED RECESS SPOT LIGHT FITTING		13A TWIN SWITCH SOCKET OUTLET	
	1 x 12w LED CEILING MOUNTED (DECO.) FITT.		TELEVISION / DSTV OUTLET	
	1 x 8w LED CEILING MOUNTED FITTING		WATER HEATER POINT	
	CEILING FAN POINT		20A DOUBLE POLE SWITCH	
	REGULATOR		EXTRACTOR FAN POINT	
	1 x 60w CEIL. MOUNTED BULB-HEAD FIT.		COOKER CONTROL UNIT	
	1 x 12w ADJUSTABLE WAR DROP LIGHTING FIT.		BELL / ALARM RING POINT	
			DOOR BELL PUSH / PHONE DEVICE	
SWITCHES			DISTRIBUTION BOARD	ALL LIGHTING SWITCHES ARE TO BE AT 1500mm ABOVE THE FINISH FLOOR, WHILE THE CABLE SIZE IS 1.5 mm sq PVC SINGLE CORE CABLE.
	1 GANG 1 WAY SWITCH		P.H.C.N METER	
	1 GANG 2 WAY SWITCH		20A SWITCH GEAR @ 2225 HEIGHT	
	2 GANG 1 WAY SWITCH		MAIN DISTRIBUTION PANEL	
	2 GANG 2 WAY SWITCH			
	3 GANG 1 WAY SWITCH			
	2 WAY PULL BED SWITCH			

Project:

LAGOS HOMES

Lagos Homes Agencies:

- New Town Development Authority (NTDA)
- Ministry Of Housing (MOH)
- Lagos State Development & Property Corporation (L.S.D.P.C)
- Project Implementation Monitoring Unit (PIMU)



LAGOS STATE GOVERNMENT

DEVELOPER:

LAGOS STATE DEVELOPMENT AND PROPRATION CORPORATION

2/4 Town Planning/Moy, Ilupeju, PMB 21950 Ikeja, Lagos
 Email: info@ldpc.gov.ng
 Website: http://www.ldsdp.gov.ng

NOTES & SPECIFICATION

1. THE DRAWINGS AND THE DESIGN ONLINE THEREIN SHALL BE THE PROPERTY OF THE DEVELOPER AND COPYRIGHT IS RESERVED.
2. ALL DIMENSIONS ARE TAKEN FROM CENTER LINES UNLESS OTHERWISE SPECIFIED.
3. ALL DIMENSIONS MUST BE CHECKED ON SITE BEFORE COMMENCING WORK.
4. THE SETTING OUT OF THIS BUILDING MUST BE APPROVED BY THE ARCHITECT OR DESIGNER REPRESENTATIVE ON SITE.

REVISIONS

NO.	DATE	REVISIONS

LAGOS HOMES ARCHITECTURAL

Design by: N.T.S.
 Date: DEC. 2020
 Drawing Title: L E G E N D

Sheet No: 00

Drawing Code: LH/MB/01

Scale: